



Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial

☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

Inspection requested by: LE RACCORDEMENT

BV Inspection performed as Recognized Authority: ☒ No ☐ Yes (....specify what recognition....)

P/o nr:
(client to BV)

P/o nr:
(client to Manufacturer)

Inspection performed on: (Date)

Location:

Previous Inspection: (Date)

Next Inspection: (Date)

MATERIAL / SUPPLY / SUBJECT OF INSPECTION	ITEM / TAG Nr	QTY
LR Elbow 90°1.5D		01
REDUCER CONCENTRIC		01
TEE EQUAL		01
CAP		01

REFERENCE DOCUMENTS: See continuation sheet for additional documents: ☐ Yes ☒ No

Title	Reference n°	Rev.	Approved by	Date
FACTORY-MADE WROUGHT BUTTWELDING FITTINGS	ASME B16.9	2001		2001

INSPECTION RESULT

☒ Satisfactory ☐ Unsatisfactory: Non Conformities Raised (Total number of NCR :.....)

BV Inspector: Nouredine BEN YAHIA TEN

BV Coordinator: Mohamed Marouane ESSID

BV Office: TUNISIA

Attachments:

☐ Yes (Total number of pages:) ☒ No

Distribution: ☒ CLIENT ☐ MANUFACTURER ☐ BV ☐ OTHER (specify)

Stage of inspection :

☐ Before manufacturing

☐ During manufacturing

☒ Final

☐ Packing

Type of inspection :

- ☐ Pre-inspection meeting ☐ Document and QC record review ☐ Visual examination, checks
☒ Witnessing tests ☐ Manufacturing progress status ☐ Vendor assessment
☐ Final inspection ☐ Packing

Stamping :

☒ No

☐

☐



Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial

☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

Results of inspection :

☒ Satisfactory ☐ Unsatisfactory

Non Conformities Reports (NCR):

o NCR's issued during reported period : none

o List of outstanding NCR's : None

Main Conclusions & Remarks: (for details see continuation sheet)

None

Next visit scheduled: none

INSPECTION DETAILS:

ATTENDEES : See continuation sheet for additional documents: ☐ Yes ☒ No

Name	Company	Title (*)	Note

(*) specify if BV inspector has role as supervisor or mentor (e.g. "BV Inspector – supervisor –")

MEASURING EQUIPMENT USED: See continuation sheet for additional documents: ☐ Yes ☒ No

Equipment Type	Equipment Identity n°	Last Calibration date	Expiry date
CALIPER	PAC 01	19/04/2018	18/04/2019
CALIPER	050442	17/01/2018	16/01/2019

Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial

☐ Interim


☒ Final

Rev. n°: 01

Reason of revision:

Description of the inspections carried out :

1. Equal Tee



Tee (Equal)

a. Dimension tolerance:

		Theoretical value	Tolerance interval	Measured	Difference
Outside diameter at bevel OD	OD1	88.9	± 1.6	89.45	0.55
	OD2	88.9		89.71	0.81
	OD3	88.9		89.06	0.16
Inside diameter at bevel d	d1	76.86	± 1.6	76.00	-0.86
	d2	76.86		76.26	-0.60
	d3	76.86		76.27	-0.59



Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial

☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

		Theoretical value	Tolerance interval	Measured	Difference
Wall thickness T	T1	6.02	-12%	6.44	+7%
	T2	6.02		6.72	+11%
	T3	6.02		5.92	-1.6%
Center to end C	C1	86	±2	85.40	-0.60
	C2	86		85.26	-0.74
Center to end M	M	86	±2	85.05	-0.95

b. Angularity tolerance:

		Theoretical value	Tolerance interval	Measured value	Difference
Off angle	Q	0	±1	0	0

c. End bevel tolerance:

		Theoretical value	Tolerance interval	Measured value	Difference
Bevel end	A	37.5°	±2.5°	37°	-0.5°
	ID	1.6	±0.8	1.76	0.16

d. Mechanical test tolerance:

	Tensile strength		Yield strength		Elongation		Hardness	
Tolerances	Min	Max	Min	Max	Min		Brinell	Rockwell
	415 MPa	585 MPa	240 MPa	-	L30	T20	Max 197 HB	Maxi 92.8 HR 15N
Measured values							142	-

Industry & Facilities Division
3° Party Shop Inspection Services



**BUREAU
VERITAS**

Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial

☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial


☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

2. Reducer concentric



Reducer (Concentric)

a. Dimension tolerance:

		Theoretical value	Tolerance interval	Measured	Difference
Outside diameter at bevel OD	OD1	88.9	±1.6	88.10	-0.8
	OD2	60.3		60.59	0.29
Inside diameter at bevel d	d1	76.86	±1.6	76.58	-0.3
	d2	49.32		49.40	0.08
Wall thickness T	T1	6.02	-12.5%	6.07	0.8%
	T2	5.49		5.55	1%



Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial

☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

end to end length	H	89	±2	88.47	-0.53
-------------------	---	----	----	-------	-------

b. End bevel tolerance:

		Theoretical value	Tolerance interval	Measured value	Difference
Bevel end	A	37.5°	±2.5°	35°	-2.5°
	ID	1.6	±0.8	1.96	0.36

c. Mechanical test tolerance:

	Tensile strength		Yield strength		Elongation		Hardness	
Tolerances	Min	Max	Min	Max	Min		Brinell	Rockwell
	415 MPa	585 MPa	240 MPa	-	L30	T20	197 HB	Maxi 92.8 HR 15N
Measured values							167	-

Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial


☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

3. LR ELBOW 90° 1.5 D



90° Elbow

d. Dimension tolerance:

		Theoretical value	Tolerance interval	Measured	Difference
Outside diameter at bevel OD	OD1	88.9	+1.6	89.28	0.38
	OD2	88.9	-0.8	89.47	0.57
Inside diameter at bevel d	d1	77.92	±0.8	77.52	-0.40
	d2	77.92		77.86	-0.06
Wall thickness T	T	6.02	-12.5%	5.49	-8.8%
Center to end length	A1	133	±2	133	0
	A2	133		132	-1



Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial

☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

e. End bevel tolerance:

		Theoretical value	Tolerance interval	Measured value	Difference
Bevel end	A	37.5°	±2.5°	35°	-2.5°
	ID	1.6	±0.8	1.96	0.36

f. Angularity tolerance:

		Theoretical value	Tolerance interval	Measured value	Difference
Off angle	Q	0	±1	0	0
Off plane	P	0	±2	0	0

g. Mechanical test tolerance:

	Tensile strength		Yield strength		Elongation		Hardness	
Tolerances	Min	Max	Min	Max	Min		Brinell	Rockwell
	415 MPa	585 MPa	240 MPa	-	L30	T20	Max 197 HB	Maxi 92.8 HR 15N
Measured values							161	-

Inspection Report N°: 40-20189-0065/01

Date of issuance:

18/07/2018

☐ Initial


☐ Interim

☒ Final

Rev. n°: 01

Reason of revision:

4. CAP



Cap

a. Dimension tolerance:

		Theoretical value	Tolerance interval	Measured	Difference
Outside diameter at bevel OD	OD	114.3	±1.6	114.35	0.05
Inside diameter at bevel d	d	102.26	±0.8	102.21	0.01
Wall thickness T	T	8.56	-12.5%	7.89	-8%
length	E	64	±2	62.7	-1.3

b. End bevel tolerance:

		Theoretical value	Tolerance interval	Measured value	Difference
Bevel end	A	37.5°	±2.5°	36°	-1.5°
	ID	1.6	±0.8	2.29	0.69

c. Mechanical test tolerance

	Tensile strength		Yield strength		Elongation		Hardness	
Tolerances	Min	Max	Min	Max	Min		Brinell	Rockwell
	415 MPa	585 MPa	240 MPa	-	L30	T20	Max 197 HB	Maxi 92.8 HR 15N
Measured values							180	-



Inspection Report N°: 40-20189-0065/01		Date of issuance:	18/07/2018
☐ Initial	☐ Interim	☒ Final	
Rev. n°: 01		Reason of revision:	

5. Conclusion



All the tests' results presented above demonstrate that the test fitting are compliant with the norm ASME B16.9 : "FACTORY-MADE WROUGHT BUTTWELDING FITTINGS"



INSPECTION REPORT N°40-2018-0065/01

BV Job nr: 40-2018-0065	Date of issuance:	Page 12 of 12
Project:	Ref:	
BV Client: LE RACCORDEMENT	Manufacturer / Vendor:	

END OF REPORT

Inspected by: Name: Nouredine BEN YAHIA TEN Signature:... 	Checked by: Name: Mohamed Marouane ESSID Signature:... 
Inspection Office: BV TUNISIA	Supervision during performance ☒ No ☐ Yes

This template is intended exclusively when BV is acting as 3° party inspection body. The use of present template is forbidden in the frame of 2° party services where Client specification and templates must be used.